

I-195 REDEVELOPMENT DISTRICT

**RESOLUTION REGARDING APPROVAL OF MINIMUM FIRST STORY HEIGHT WAIVER
FOR PARCEL 2**

November 6, 2024

WHEREAS: Pursuant to the Rhode Island Special Economic Development District Enabling Act (the “SEDD Act”), the Commission is charged with approving all plans for development within the I-195 Redevelopment District; and

WHEREAS: Pursuant to the SEDD Act, the Commission adopted a Development Plan on May 20, 2020 (the “2020 Development Plan”) applicable to construction with the I-195 Redevelopment District which 2020 Development Plan has been superseded by a Development Plan adopted by the Commission on September 20, 2023 (the “2023 Development Plan”); and

WHEREAS: Collage Development LLC (“Collage”), the proposed purchaser of Parcel 2, began the design review process under the 2020 Development Plan; and


WHEREAS: The Commission has received a design review application from Collage in which Collage requests a waiver from the provisions of *Section 2.3, Table 2.3-1* of the 2020 Development Plan with respect to minimum first story height for a non-residential use (the “Waiver”), for so-called Building A; and

WHEREAS: Utile, Inc. (“Utile”), the District’s design consultant, has determined that the Waiver is appropriate and has recommended by letter dated November __, 2024, a copy of which letter is attached hereto as Exhibit A and is incorporated herein by reference (the “Utile Letter”) that the District grant the Waiver; and

WHEREAS: At a public hearing held this date, following publication and notice to abutters as required by applicable law, the Commission heard presentations by Collage and Utile with respect to the Waiver.

NOW, THEREFORE, acting by and through its Commissioners, the District hereby resolves as follows:

RESOLVED: That the District hereby (a) finds that, given the geography of Parcel 2, enforcement of the minimum first story height regulations for a non-residential use contained in the 2020 Development Plan would preclude the full enjoyment by the owner of a permitted use and amount to more than a mere inconvenience, (b) adopts the recommendations contained in the Utile letter with respect to the Waiver and (c) grants the Waiver.



Marc A. Crisafulli, Chairperson
November 6, 2024

EXHIBIT A

UTILE LETTER

utile

November 6, 2024

Caroline Skundk, Executive Director
I-195 Redevelopment District Commission
225 Dyer Street, Fourth Floor,
Providence, RI 02903

RE: Parcel 2 - Waiver for Minimum First Story Height (Building A - North Building)

Dear Caroline,

Utile, the I-195 Redevelopment District's Urban Design and Planning consultant, recommends that the Commission grant a waiver to the Minimum First Story Height for Building A (the north building) of Urbanica's proposal for Parcel 2 for the reasons described below.

The Commission previously granted a waiver to the Minimum First Story Height from 18' to 14' for the south building. The waiver currently requested relates to the former live-work units in the north building.

Recommendation to Grant New Waiver

Urbanica's proposal previously included live-work units in the north building consisting of a commercial ground floor and residential mezzanine set back from the exterior wall totalling 18' in height. Urbanica is now proposing to modify the plan for these units to have fully separate floors - a commercial ground floor with a height of 9' and a residential second floor with a height of 8' (totalling 18', inclusive of a 1' allowance for floor thickness).

Utile recommends that the Commission grant a new waiver allowing the Minimum First Story Height (Table 2.3-1) for the former live-work units in the north building to be reduced from the 18' minimum first story height required under the original Development Plan to 9' for the following three reasons:

1. Balancing First Story Height with Overall Building Height - Given community sensitivity to height at this location, there is a need to balance first story height with overall building height. The proposed solution results in no change to the overall building height and no change to the combined height of the first and second "mezzanine" floors of the live-work units.
2. Minimal Impact on Exterior Elevation - Since the ground floor live-work units were originally conceptualized with "mezzanine" floors that were visually signaled by exterior window mullions and projecting canopies with continuous floor to ceiling windows, the subdivision of these units into two fully separate

Architecture
& Planning

115 Kingston St.
Boston, MA 02111

110 Union St.
Providence, RI 02903

(617) 423-7200
utilidesign.com

utile

floors has no impact on the exterior perception. The proposed design change still gives the illusion of an 18' first story height.

3. Consistency with Updated Development Plan - Due to the significant grade change and multiple buildings, the application of Minimum First Story Height requirements as defined in the 2020 Development Plan is unclear and overly complex. However, Urbanica's development proposal is generally consistent with the 2023 Development Plan governing future development in the District, which clarified the application of Minimum First Story Height.

As the design progresses in resolution, Utile recommends that the Urbanica team develop and share with the District a proactive approach to address two new design questions raised by this change:

1. How does the design address privacy and the exterior look of the second floor residential units that now include floor-to-ceiling windows lining occupable interior residential space?
2. How does the design incorporate signage for the ground floor commercial of the live/work units without negatively impacting the design and experience of the second floor residential units?

This should be addressed in advance of the Issuing of construction documents.

Please do not hesitate to reach out if you have questions or would like additional information.

Regards,



Tim Love, Principal
Utile
115 Kingston Street
Boston, MA 02111

Architecture
& Planning

115 Kingston St.
Boston, MA 02111

110 Union St.
Providence, RI 02903

(617) 423-7200
utile.design.com